



Safety & Buildings Division
201 West Washington Avenue
P.O. Box 2658
Madison, WI 53701-2658

Evaluation #

200272-H

Wisconsin Building Product Evaluation

Unit Heaters:

Manufacturer: Thomas & Betts Corporation, Reznor Div.
150 McKinley Ave.
Mercer, PA 16137

Approved Product(s): Trade Name: **Reznor V3 Series**

Model Numbers: UDBP 30, 45, 60, 75, 100, 125, 150, 175,
200, 225, 250, 300 & 350.

UDBS 30, 45, 60, 75, 100, 125, 150, 175,
200, 225, 250, 300 & 350.

SCOPE OF EVALUATION: This review includes the cited:
Comm code requirements in accordance with the current
**Wisconsin Dwelling Code (UDC); International Building
Code (IBC); International Mechanical Code (IMC); and
International Fuel Gas Code (IFGC).**

TESTS: The unit heaters were tested in accordance with ANSI
Z83.8b Standard for Gas Unit Heaters and Gas-Fired Duct
Furnaces, and CSA International 10.96 US Standard for Unit
Heater for Residential Use. The equipment is listed and
certified by CSA International.

LIMITATIONS OF APPROVAL: The unit heaters shall be
installed as allowed in **s. Comm 23.04** of the **UDC**; **s. IBC
302.1**; **ss. IMC 301, 303, and 920**; **s. IFGC 619**, their listing
and the manufacturer's recommendations.

Suspended equipment shall also be installed as allowed by the
particular occupancy chapter.

This approval will be valid through December 31, 2007, unless
manufacturing modifications are made to the product or a re-
examination is deemed necessary by the department.

The Wisconsin Building Products Evaluation number must be
provided when plans that include this product are submitted for
review.

DISCLAIMER: The department is in no way endorsing or
advertising this product. This approval addresses only the
specified applications for the product and does not waive any
code requirement not specified in this document.

Revision Date:

Approval Date: April 4, 2003 By:

Lee E. Finley, Jr.
Product/Material &
Building Plan Review
Integrated Services Bureau

200272-H.doc